CITY OF VALDEZ
Project: Civic Center Interior Painting
Project No.: 13-350-1307
Contract No.: 1120

TO: **All Recipients** **Date: July 2, 2013**

SUBJECT: **Addendum No.2**

This 1 page Addendum forms a part of the project scope documents and modifies the project scope for the above-referenced project. **Acknowledge receipt of this Addendum in the space provided on the Bid Form**. Failure to do so may subject the Bidder to disqualification.

This Addendum makes the following changes and/or clarifications:

1. The Drawing Reference Plan denotes there is a janitorial closet and stairwell included within the Equipment Room Area and Kitchen located in AA3. Please make sure to include the additional verbiage on the Bid Schedule and Contract for AA3 to read:

   AA3- Painting to include Kitchen, Janitorial Closet, Equipment Rm. and Stairwell leading to above.

2. Under Specification Section 09 91 00-9 Part 3.11 Finish Schedule
   Note change has been made to read:

   1. Below chair rails, trim and stair railings and steel doors will be Devoe Paint Interior Semi Gloss Paint RGN54XX or approved equal.
      (Oil based paint will no longer be used on this project)

3. Under Special Provisions SP 04 Special Site Conditions (Pg. 27)
   Add verbiage to contract to read:

   A minimum of 1 employee must be hold a current First Aid/ CPR certification card and be on-site at all times while work is being performed. Anyone operating a lift or scaffolding must have current certification. The certification cards will be checked by the city's Project Manager prior to the start of any work.

   All OSHA requirements must be met by the applicator of the paint.

   End of Addendum